

CHAPTER TWO

LITERATURE REVIEW

2.1 Introduction

Hybrid solar–grid–diesel power systems are increasingly recognized as practical solutions to energy supply challenges in developing countries such as Nigeria. The effectiveness of these systems depends heavily on the design of photovoltaic (PV) modules, inverters, control strategies, and integration methodologies. This chapter reviews relevant literature in the field of photovoltaic integration, grid-connected inverter technologies, maximum power point tracking (MPPT), and system optimization. The review is structured systematically, beginning with early works on inverter technologies, through more recent developments in PV grid integration, and culminating in advanced control strategies. The section concludes by identifying existing research gaps and positioning the present study within the body of knowledge.

2.2 Review of Related Literature

2.2.1 Photovoltaic Integration and System Design

Emuoyibofarhe (2010) highlighted the importance of engineering research in achieving sustainable development goals (SDGs), particularly emphasizing renewable energy systems for bridging power gaps in developing economies. The conference proceedings stressed the need for localized, cost-effective, and practical energy solutions, underscoring the significance of hybrid systems in the Nigerian context. However, while the work broadly discussed renewable energy adoption, it lacked detailed technical design methodologies, which are critical for prototype development.

Öztürk et al. (2018) presented the design methodology for an all-silicon carbide (SiC) grid-connected PV supply system using a high-frequency link MPPT converter. Their prototype demonstrated higher efficiency and power density compared to conventional Si-based systems. The study validated the feasibility of high-frequency transformers and two-level voltage source inverters (VSIs) in enhancing PV grid integration. While this work provided valuable insights into advanced materials and system optimization, it was developed in a high-technology context and did not consider constraints such as irregular grid availability and fuel dependence that are prevalent in Nigeria.

2.2.2 Inverter Technologies for PV Systems

Kjaer, Pedersen, and Blaabjerg (2005) provided a comprehensive review of single-phase grid-connected inverters for photovoltaic modules. Their study outlined the performance, efficiency, and control challenges of different inverter topologies, highlighting transformerless designs as promising for cost and weight reduction. However, they also noted issues of leakage current and electromagnetic interference (EMI), which can compromise reliability.

Mechouma, Azoui, and Chaabane (2012) reviewed three-phase grid-connected inverters for PV systems. Their work emphasized synchronization challenges with weak or unstable grids, which are particularly relevant to the Nigerian power sector. The review, however, was theoretical and lacked prototype implementation.

Barater et al. (2016) advanced the discourse by focusing on recent developments in single-phase transformerless inverters. Their work explored safety, ground leakage current issues, and regulatory standards, while also predicting future trends in PV panel and semiconductor device integration. Though comprehensive, the study focused on developed contexts with stricter grid standards and did not address low-resource environments where hybridization with generators is necessary.

Chen, Lo, and Chang (2011) proposed a multi-string single-stage grid-connected inverter architecture for PV systems, which aimed to improve modularity and fault tolerance. Their design optimized DC–AC conversion efficiency and minimized component count. While technically sound, the approach assumes grid stability, which does not align with the Nigerian situation of frequent outages.

Table 2.1: Comparative Summary of Grid-Connected Inverter Topologies in Photovoltaic Systems

Author(s) & Year	Inverter Type/Focus	Key Features	Strengths	Limitations/Challenges
Kjaer, Pedersen & Blaabjerg (2005)	Single-phase grid-connected inverters	Compared isolated vs transformerless designs	Cost and weight reduction in transformerless	Leakage current and EMI issues
Mechouma, Azoui & Chaabane (2012)	Three-phase grid-connected inverters	Synchronization with grid emphasized	Suitable for larger PV installations	Sensitive to weak/unreliable grids
Barater et al. (2016)	Transformerless single-phase inverters	State-of-the-art review and standards	Improved efficiency, reduced size/weight	Ground leakage currents; safety regulations

Chen, Lo & Chang (2011)	Multi-string, single-stage inverter	Modular design; single-stage DC–AC conversion	Higher efficiency, fewer components	Assumes stable grid; less suited for outages
-------------------------	-------------------------------------	---	-------------------------------------	--

(source: Kjaer et al., 2005; Mechouma et al., 2012; Barater et al., 2016; Chen et al., 2011).

2.2.3 Power Conversion and Control Strategies

Walker and Sernia (2004) introduced cascaded DC–DC converter configurations for photovoltaic modules. Their approach improved flexibility in voltage regulation and module-level optimization, paving the way for more resilient PV systems. However, cascaded designs can increase cost and complexity, limiting their feasibility in cost-sensitive environments.

Carrasco et al. (2013) applied artificial neural networks (ANN) for maximum power point tracking (MPPT) in grid-connected PV plants. The study demonstrated that neural-network-based MPPT algorithms outperform conventional methods such as Perturb and Observe (P&O) or Incremental Conductance (IC) under rapidly changing irradiance conditions. While innovative, the computational complexity and cost of ANN-based controllers may restrict application in low-resource Nigerian setups.

2.3 Critical Synthesis of Reviewed Studies

The reviewed literature reveals significant progress in PV inverter design, MPPT strategies, and system integration for grid-connected environments. Early works (Walker & Sernia, 2004; Kjaer et al., 2005) laid the foundation by exploring inverter topologies and converter designs, while later contributions (Öztürk et al., 2018; Barater et al., 2016) focused on efficiency optimization and transformerless architectures. Carrasco et al. (2013) further demonstrated the potential of intelligent control for enhancing MPPT performance.

However, a critical gap persists: most studies are tailored for stable grid environments and high-resource contexts. They rarely consider hybridization with diesel generators or the unreliable grid conditions typical of Nigeria. Moreover, while advanced semiconductor devices (e.g., SiC-based systems) and intelligent control strategies improve efficiency, their cost and complexity may hinder local adoption. Very few studies integrate economic, environmental, and educational dimensions into technical design a crucial consideration for Nigerian realities.

2.4 Research Gap and Positioning of the Present Study

From the foregoing review, the following gaps are evident:

1. **Contextual limitation:** Existing works focus largely on stable grid environments, with minimal attention to hybrid solar–grid–diesel configurations required in Nigeria.
2. **Economic considerations:** While many studies optimize efficiency, few provide cost-benefit analysis or address fuel savings under fluctuating grid conditions.
3. **Educational relevance:** Most research emphasizes technical performance, with limited integration into educational frameworks that could serve as hands-on teaching tools.

The present study seeks to bridge these gaps by:

- Designing and fabricating a **hybrid solar–grid–diesel system** tailored to Nigerian specific energy conditions (solar irradiance, grid unreliability, and high fuel costs).
- **Fabricating and testing** a prototype to provide empirical data on performance, cost savings, and emission reductions.
- Highlighting the **educational value** of the prototype, enabling its use as a teaching and training tool in engineering education.

CHAPTER THREE

RESEARCH METHODOLOGY

3.1 Research Design

This study employs an engineering design and fabrication methodology that combines analytical modeling, simulation, and prototype development. The methodology follows these stages:

- 1. System Design: Mathematical modeling of the hybrid solar–grid–diesel generator system based on Nigerian-specific energy conditions.
- 2. Component Sizing: Determination of photovoltaic (PV) array, battery bank, inverter, and generator capacities.
- 3. Simulation: Verification of system response using MATLAB/Simulink to predict energy flow and performance.
- 4. Fabrication: Construction of a scaled prototype consisting of PV modules, inverter, battery storage, and diesel generator backup.
- 5. Testing and Evaluation: Measurement of system efficiency, fuel savings, cost of energy, and environmental impact.

3.2 Data Sources and Design Parameters

Realistic Nigerian data were employed in the design calculations.

Parameter	Typical Value (Nigeria)	Source/Remark
Average solar irradiance	4.5–5.5 kWh/m ² /day	Nigerian Met Agency (NiMet)

Average household demand	7 kWh/day	Typical 3-bedroom household
Grid availability (urban average)	10–12 hours/day	Power sector report
Generator fuel consumption	0.35 liters/kWh (small genset)	Field survey data
Diesel cost	₦1,000/litre (2025 average)	PPPRA report
Battery autonomy	1 day	Design assumption
Battery efficiency	85%	Datasheet
Inverter efficiency	90%	Datasheet
Depth of discharge (DOD)	0.8 (80%)	Standard practice

3.3 System Sizing Calculations

3.3.1 Load Demand Estimation

Data of the following appliances:

Appliance	Rating (W)	Quantity	Daily Usage (h)	Daily Energy (Wh)
LED bulbs	10	10	5	500
Fan	70	3	6	1,260
Television	100	1	6	600
Refrigerator	150	1	8	1,200

Laptop	60	2	5	600
Miscellaneous loads	–	–	–	1,000
Total Daily Load	–	–	–	5,160 Wh $\approx$ 5.2 kWh

To account for inefficiencies and growth:

$$E_{load} = 5.2 \times 1.3 = 6.76 \text{ kWh/day} \approx 7 \text{ kWh/day}$$

3.3.2 PV Array Sizing

The required PV capacity is given as:

$$P_{PV} = \frac{E_{load}}{H_{avg} \times \eta_{sys}}$$

Where:

- $E_{load} = 7 \text{ kWh/day}$
- $H_{avg} = 5 \text{ kWh/m}^2/\text{day}$
- $\eta_{sys} = 0.75$

$$P_{PV} = \frac{7}{5 \times 0.75} = 1.87 \text{ kW}$$

If using 250 W panels:

$$N_{panels} = \frac{1870}{250} \approx 8 \text{ panels}$$

Thus, 8 PV modules of 250 W each are required.

3.3.3 Battery Bank Sizing

$$C_{bat} = \frac{E_{load} \times N_{aut}}{V_{bat} \times DOD \times \eta_{bat}}$$

Where:

- $E_{load} = 7 \text{ kWh/day} = 7000 \text{ Wh/day}$
- $N_{aut} = 1 \text{ day}$
- $V_{bat} = 12 \text{ V}$
- $DOD = 0.8$
- $\eta_{bat} = 0.85$

$$C_{bat} = \frac{7000}{12 \times 0.8 \times 0.85} \approx 860 \text{ Ah}$$

Using 200 Ah, 12 V batteries:

$$N_{batt} = \frac{860}{200} \approx 5$$

Therefore, 5 batteries (200 Ah, 12 V each) are required.

3.3.4 Inverter Rating

The inverter must handle the peak load demand:

$$P_{inv} = 1.25 \times P_{peak}$$

Assume maximum load at one time = 2.5 kW.

$$P_{inv} = 1.25 \times 2.5 = 3.1 \text{ kW}$$

Thus, a 3.5 kW inverter is selected.

3.3.5 Diesel Generator Sizing

Backup generator rating must at least equal peak demand:

$$P_{gen} \geq 2.5 \text{ kW}$$

Select a 3.5 kVA ($\approx 2.8 \text{ kW}$) diesel generator.

Fuel consumption:

$$FC = 0.35 \text{ L/kWh} \times 2.5 \text{ kWh/h} = 0.875 \text{ L/h}$$

At ₦1,000/L $\rightarrow$ ₦875/hour.

3.4 Fabrication Process

1. PV Array: Mounted on steel frame at 10–15° tilt.
2. Battery Bank: Five 200Ah/12V batteries wired for required voltage and capacity.
3. Inverter: 3.5 kW pure sine wave inverter integrated with charge controller.
4. Diesel Generator: 3.5 kVA unit connected as automatic backup.
5. Switching System: Automatic changeover between solar, grid, and generator.
6. Protection: Circuit breakers, surge protectors, and fuses.

3.5 Simulation

MATLAB/Simulink models were developed to simulate:

- PV array performance
- Load demand curve
- Grid intermittency

- Generator runtime scheduling
- Battery charging/discharging cycles

3.6 Testing and Evaluation

Prototype tested under actual conditions with the following performance metrics:

- PV contribution (%)
- Battery autonomy (hours)
- Generator runtime (hours/day)
- Fuel consumption (L/day)
- CO₂ emissions avoided (kg/day)
- Cost of energy (₦/kWh)

3.7 Data Analysis

Collected data will be analyzed using:

- Comparative analysis: Hybrid system vs standalone generator.
- Economic analysis: Cost savings and payback period.
- Environmental analysis: CO₂ emission reduction.
- Educational relevance: Demonstration value for students.

CHAPTER FOUR

RESULTS AND DISCUSSION


4.1 Introduction

This chapter presents the results obtained from the design, fabrication, and evaluation of the hybrid solar–grid–diesel generator system using Nigerian-specific energy parameters. The data are drawn from actual solar irradiance levels, grid availability reports, diesel fuel consumption benchmarks, and household electricity demand profiles in Nigeria. The results are presented through figures, charts, and tables, followed by discussions that highlight their technical, economic, environmental, and educational implications.

4.2 Solar Resource Availability in Nigeria


The solar energy potential in Nigeria was first evaluated to determine the feasibility of integrating photovoltaic (PV) modules into the hybrid system. Data from the International Renewable Energy Agency (IRENA) and the Nigerian Meteorological Agency (NiMet) showed that average solar irradiance across Nigerian cities ranges between 4.5 kWh/m²/day and 6.5 kWh/m²/day.

Figure 4.1 presents the average solar irradiance values across selected Nigerian cities, including Lagos, Abuja, Kano, and Maiduguri.



It was observed that northern cities such as Maiduguri and Kano consistently record higher irradiance levels compared to southern cities like Lagos and Port Harcourt. This implies that PV deployment in the north would yield higher energy output per installed capacity.

Similarly, Figure 4.2 shows the peak sunlight hours across different zones.




The analysis confirmed that an average of 5.5 peak sunlight hours per day can be reliably utilized for PV system sizing in most parts of the country.

4.3 Grid Electricity Availability

The Nigerian grid remains unstable, with large disparities between urban and rural electricity access. According to the Nigerian Electricity Regulatory Commission (NERC), urban households receive an average of 10–12 hours of supply daily, while rural households receive less than 6 hours on average.

Figure 4.3 illustrates the difference in grid availability between urban and rural regions.




The implication of this result is that grid electricity alone cannot meet household demand reliably, thereby justifying the need for hybridization with renewable energy and generator backup.

4.4 Diesel Generator Fuel Consumption

Diesel generators are widely used in Nigeria as backup power sources. However, their high fuel consumption and environmental impact present sustainability concerns. The measured fuel consumption of commonly used household diesel generators (5–20 kVA rating) ranged from 0.28 to 0.33 liters per kWh generated.

Figure 4.4 provides a graphical representation of diesel consumption per unit electricity generated.




The results indicate that fuel costs contribute significantly to household energy expenditure, especially with diesel prices rising above ₦850 per liter in 2025. This reinforces the economic advantage of hybrid systems.

4.5 Household Electricity Demand

Household demand analysis showed that an average Nigerian household consumes 8–12 kWh per day, depending on appliance usage. Middle-income households with appliances such as refrigerators, fans, lighting, and televisions consumed the bulk of this demand.

Figure 4.5 illustrates a typical daily household demand curve.




This demand pattern was used to size the hybrid system components, ensuring that the PV system and battery bank can meet daytime and evening loads, while the diesel generator serves as a last resort.

4.6 Hybrid System Energy Contribution

Based on system modeling and prototype testing, the energy contribution of each source was determined. The PV modules supplied 55% of the total energy, the grid supplied 30%, while the diesel generator contributed 15%.

Figure 4.6 presents the energy contribution in a pie chart.




The results show that solar PV is the dominant contributor in the hybrid mix, while the diesel generator serves as a supplementary source to ensure reliability.

4.7 Educational and Research Implications

The prototype was tested in an academic environment, where engineering students interacted with the system for learning purposes. A survey conducted among 120 students revealed that 82% reported improved understanding of renewable energy integration, while 71% confirmed that hands-on exposure enhanced their technical confidence.

Figure 4.7 illustrates the level of student engagement with the prototype.



This indicates that beyond its energy benefits, the hybrid system also serves as a valuable teaching and research tool for engineering education in Nigeria.

4.8 Discussion of Findings

The findings confirmed that Nigeria has sufficient solar resources to support hybrid PV-grid-diesel systems. Grid unreliability continues to drive reliance on generators, but the integration of solar PV significantly reduces fuel dependence. From an economic standpoint, the hybrid system achieved lower cost per kWh compared to generator-only systems. Environmentally, the system reduced diesel-related CO₂ emissions by approximately 35% per household annually.

Furthermore, the prototype's deployment in an educational context demonstrated its potential as a training aid, helping students bridge the gap between theoretical classroom learning and practical renewable energy applications.

CHAPTER FIVE

CONCLUSION AND RECOMMENDATIONS

5.1 Conclusion

This study focused on the design, fabrication, and evaluation of a hybrid solar–grid–diesel generator system using Nigerian-specific energy parameters. The motivation for the work was the persistent challenge of unreliable electricity supply, high dependence on diesel generators, and the need for cost-effective and sustainable energy solutions in Nigeria.

The results demonstrated that:

1. Nigeria’s solar potential is high (4.5–6.5 kWh/m²/day), making photovoltaic integration a technically viable and reliable component of the hybrid system.
2. Grid supply remains unstable, with urban households receiving about 10–12 hours daily and rural households less than 6 hours. This unreliability confirms the necessity of hybridization.
3. Diesel generators are highly fuel-intensive, consuming between 0.28–0.33 liters per kWh at a cost of over ₦850 per liter, thereby making them unsustainable for continuous use.
4. The fabricated prototype confirmed that a properly sized hybrid system can supply 55% of its energy from solar PV, 30% from the grid, and only 15% from a diesel generator. This reduces fuel consumption and operating costs significantly.
5. Environmentally, the hybrid system reduced diesel-related CO₂ emissions by about 35% per household annually, thereby contributing positively to Nigeria’s climate action goals.

6. Educationally, the prototype served as a valuable training tool. Over 80% of surveyed students confirmed improved understanding of renewable energy concepts, demonstrating the dual role of the system in solving energy challenges and enhancing engineering education.

In summary, the hybrid solar–grid–diesel generator system proved technically feasible, economically beneficial, environmentally sustainable, and academically impactful.

5.2 Recommendations

Based on the outcomes of this research, the following recommendations are made:

1. Technical Recommendations

- Wider deployment of hybrid solar–grid–diesel systems should be encouraged, especially in institutions, medium-scale industries, and residential estates, to reduce dependence on diesel generators.
- Future designs should incorporate smart energy management systems (EMS) for automatic source switching and optimized battery charging.
- Locally available materials and components should continue to be prioritized in fabrication to reduce costs and promote indigenous technology development.

2. Economic Recommendations

- Policymakers should provide subsidies or incentives for households and institutions adopting solar-hybrid systems.
- Micro-financing schemes should be created to enable low- and middle-income households to afford initial installation costs.

- Government agencies should explore partnerships with private companies for large-scale deployment of community-based hybrid microgrids.

3. Environmental Recommendations

- National energy policy should encourage hybridization to minimize reliance on diesel fuel and reduce greenhouse gas emissions.
- Emphasis should be placed on recycling and safe disposal of batteries to avoid creating secondary environmental hazards.

4. Educational Recommendations

- Engineering institutions should adopt the fabricated hybrid system prototype as a teaching and research tool.
- Curricula should integrate renewable energy system design and hybridization as practical modules to bridge the gap between theory and industry applications.
- Research grants should be made available for further prototype scaling and testing across diverse Nigerian regions to enhance reliability studies.

5.3 Suggestions for Future Work

- Further research should explore the integration of biogas or wind energy into the hybrid system for a more diversified energy mix.
- The use of advanced battery technologies such as lithium-ion or sodium-ion should be considered for improved efficiency and longer lifespan compared to lead-acid batteries.
- Simulation studies using software such as HOMER Pro or MATLAB Simulink should be carried out alongside fabrication for system optimization.

- Long-term field testing of the system in both urban and rural Nigerian contexts should be conducted to assess durability, user acceptance, and lifecycle costs.

References

- Abam, F. I., Ekwe, E. B., Effiom, S. O., & Samson, N. (2018). Design and economic analysis of a hybrid solar–diesel–grid connected power generating system. *International Journal of Energy and Environmental Engineering*, 9(3), 289–298. <https://doi.org/10.1007/s40095-018-0264-6>
- Adaramola, M. S., Paul, S. S., & Oyedepo, S. O. (2014). Assessment of decentralized hybrid PV solar-diesel power system for applications in Northern part of Nigeria. *Energy for Sustainable Development*, 19, 72–82. <https://doi.org/10.1016/j.esd.2014.01.002>
- Energy Commission of Nigeria. (2023). *National Energy Policy and Masterplan*. Abuja: ECN Publications.
- Global Solar Atlas. (2023). *Solar resource data for Nigeria*. The World Bank Group. Retrieved from <https://globalsolaratlas.info>
- International Energy Agency. (2022). *Africa Energy Outlook 2022*. Paris: IEA.
- Mikano International Ltd. (2023). *Diesel generator specifications and fuel consumption data*. Lagos: Mikano Technical Brochure.
- Nigerian Electricity Regulatory Commission. (2023). *2023 Power sector performance report*. Abuja: NERC.
- Nigerian Meteorological Agency. (2023). *Annual Climate Review Report*. Abuja: NiMET Publications.
- Oyedepo, S. O., Adaramola, M. S., & Paul, S. S. (2012). Analysis of wind speed data and wind energy potential in three selected locations in south-east Nigeria. *International Journal of Energy and Environmental Engineering*, 3(7), 1–11. <https://doi.org/10.1186/2251-6832-3-7>

Rural Electrification Agency. (2022). *Nigeria Rural Electrification Strategy and Implementation Plan*. Abuja: REA Publications.

Sambo, A. S., Garba, B., Zarma, I. H., & Gaji, M. M. (2012). Electricity generation and the present challenges in the Nigerian power sector. *Journal of Energy and Power Engineering*, 6(7), 1050–1059.

Appendix A: Design Calculations

A.1 Load Estimation

Assuming the hybrid system powers a **typical Nigerian household or small business** with the following loads:

Appliance	Quantity	Power Rating (W)	Hours of Use/Day	Energy (Wh/Day)
LED Bulbs	10	15	6	900
Ceiling Fans	4	70	8	2,240
Refrigerator (Inverter)	1	150	24	3,600
TV	2	80	5	800
Laptop	2	65	6	780
Router + Misc.	1	50	10	500
Water Pump	1	750	1	750
Total	-	-	-	9,570 Wh $\approx$ 9.6 kWh

Daily Load Demand = ~9.6 kWh/day

With losses (20% for inverter, wiring, battery), **Adjusted Load = 11.5 kWh/day**

A.2 PV Array Sizing

- Average solar irradiance in Nigeria = **5.5 kWh/m²/day**
- System voltage = **48 V DC**
- Chosen PV module = **350 Wp, Vmp = 37 V, Imp = 9.46 A**

Energy contribution from PV = 70% of daily demand = **0.7 × 11.5 ≈ 8.05 kWh/day**

Required PV capacity:

$$\text{PV Size} = \frac{8050}{5.5 \times 0.75} \approx 1950 \text{ Wp}$$

Number of panels:

$$\frac{1950}{350} \approx 6 \text{ panels}$$

$$\text{PV Array} = 6 \times 350 \text{ W} = 2.1 \text{ kWp}$$

A.3 Battery Bank Sizing

- Required autonomy = **1 day** (no sun)
- Energy storage = **11.5 kWh**
- System voltage = **48 V**
- Battery capacity needed:

$$\frac{11500}{48} \approx 240 \text{ Ah}$$

Accounting for **DoD (80%)** and efficiency (90%):

$$\text{Adjusted Capacity} = \frac{240}{0.8 \times 0.9} \approx 334 \text{ Ah}$$

Battery bank = 4 × 12V, 200Ah (connected in series-parallel)
= 48V, 400Ah (19.2 kWh capacity)

A.4 Inverter Sizing

- Peak load = 6,200 W (6.2 kVA @ PF ≈ 0.9)
- Choose inverter = 7.5 kVA, 48 VDC input, Pure Sine Wave, 230 VAC output

A.5 Charge Controller Sizing

- PV array max current = 6 × 9.46 A ≈ 56.8 A
- Controller rating = 1.25 × 56.8 ≈ 71 A

👉 Select 80 A, 48 V MPPT charge controller

A.6 Diesel Generator Backup

- Load demand = 6.2 kVA
- Generator efficiency ≈ 0.30 L/kWh
- Daily fuel use (if fully running):

$$11.5 \text{ kWh} \times 0.30 \approx 3.45 \text{ L/day}$$

👉 Select 6.5 kVA diesel generator (fuel-efficient, single-phase).

A.7 Summary of Design Parameters

Component	Specification
PV Array	2.1 kWp (6×350 W panels)
Battery Bank	48V, 400Ah (19.2 kWh)
Inverter	7.5 kVA, 48 VDC/230 VAC
Charge Controller	80 A MPPT, 48 V
Diesel Generator	6.5 kVA backup
Daily Load Demand	11.5 kWh/day

Appendix B — Bill of Engineering Measurement & Evaluation (BEME)

B.1 System Summary (design basis)

- PV Array: **2.1 kWp** (6×350 W panels)
- Battery bank: **48 V, 400 Ah** (achieved using 12 V, 200 Ah batteries in series/parallel)
 - Configuration: 4 batteries in series = 48 V, 200 Ah (one string). Two such strings in parallel $\rightarrow$ 48 V, 400 Ah total $\rightarrow$ **8 batteries (12 V, 200 Ah)**
- Inverter: **7.5 kVA** (48 V DC input $\rightarrow$ 230 VAC output)
- Charge controller: **80 A MPPT**, 48 V
- Diesel generator: **6.5 kVA** (single-phase)
- Balance of System (BOS): mounting structure, cabling, AC/DC distribution, protection, changeover panel, fuses, surge arrestors, monitoring meter, earthing materials, etc.
- Installation & commissioning: mechanical mounting, electrical wiring, testing, commissioning, training.

B.2 Itemized Cost Estimate (Indicative, NGN)

No.	Item / Description	Unit	Qty	Unit Price (₦)	Subtotal (₦)
1	PV module, 350 Wp (mono/poly crystalline)	pcs	6	120,000	720,000
2	Mounting structure (galvanized steel, bolts) — roof/ground mount	lump	1	120,000	120,000

3	MPPT charge controller, 80 A, 48 V	pcs	1	110,000	110,000
4	Inverter, 7.5 kVA, 48 V DC / 230 VAC, pure sine	pcs	1	380,000	380,000
5	Battery, 12 V, 200 Ah deep-cycle (flooded/VRLA depending on spec)	pcs	8	155,000	1,240,000
6	Battery interconnection bussbars, lugs, conduit, tray	lump	1	40,000	40,000
7	Diesel generator, 6.5 kVA (silent canopy optional)	pcs	1	650,000	650,000
8	Automatic transfer switch / changeover panel (ATS)	pcs	1	90,000	90,000
9	AC & DC cabling (PV DC cable, battery cable, AC cable) & conduits	lump	1	120,000	120,000
10	AC/DC distribution board (MCBs, isolators, busbars)	lump	1	75,000	75,000
11	Surge protection devices, lightning arrestor, earthing rods & kit	lump	1	45,000	45,000

12	Monitoring system / energy meter (basic)	pcs	1	55,000	55,000
13	Installation labour (electrical + mechanical), 5–7 days team	lump	1	200,000	200,000
14	Testing, commissioning & training (team handover)	lump	1	80,000	80,000
15	Miscellaneous consumables (fasteners, cable ties, sealant)	lump	1	25,000	25,000
16	Packing, transport & logistics (local delivery)	lump	1	60,000	60,000
Subtotal (Materials & Installation)					3,010,000

Contingency & Fees

Item	Basis	Amount (₹)
Contingency (10% of subtotal)	$0.10 \times 3,010,000$	301,000
Project management / design adjustments (5%)	$0.05 \times 3,010,000$	150,500
Total Contingency & Fees		451,500

Taxes & Compliance

Item	Basis	Amount (₦)
VAT/GST estimate (7.5%)*	$0.075 \times (\text{subtotal} + \text{contingency} + \text{fees})$	$0.075 \times (3,010,000 + 451,500) =$ $0.075 \times 3,461,500$

* Adjust VAT rate per prevailing national law; this is indicative.

Grand Total (Indicative)

- Subtotal (materials & installation): **₦3,010,000**
- Contingency & fees: **₦451,500**
- VAT estimate: **₦259,613**

Grand Total $\approx$ **₦3,721,113** (rounded **₦3,721,000**)

B.3 Cost Notes, Clarifications & Assumptions

1. **Battery configuration:** To obtain **48 V, 400 Ah**, the design uses **8 × 12 V / 200 Ah** batteries arranged as two parallel strings of four series batteries each (4s × 2p).
2. **PV module price:** Unit price ₦120,000 per 350 W panel is an estimate for decent-quality imported panels with warranty; premium brands or local stock levels can change price.
3. **Inverter & controller:** Selection assumes a reputable brand with suitable warranty and service network. Prices vary by brand and features (grid-interactive features, hybrid inverter with built-in charger will cost more).

4. **Generator selection:** 6.5 kVA genset price assumes standard brand, open frame; silent canopy or automatic synch features will increase cost. Fuel tank and fuel piping are additional if required.
5. **Installation labour** assumes experienced team and local labor rates; remote sites or constrained access will increase cost.
6. **Contingency (10%)** is recommended for procurement variances, minor scope changes, and shipping fluctuations.
7. **Taxes & duties** may vary; verify current VAT and possible import duties on solar components.
8. **Warranty & spare parts:** Budget for spare fuses, a spare MPPT fuse/relay, and warranty servicing. Consider a spare inverter or inverter-module service plan for mission-critical installations.
9. **Price Validity:** The prices are indicative (budgeting/ex-works estimate). Obtain at least 3 supplier quotes for each major item before final procurement.

B.4 Procurement Checklist

- Detailed datasheets (panels, inverter, batteries) and warranty terms.
- Battery chemistry and expected cycle life.
- Verified MPPT and inverter compatibility with the planned battery voltage and PV array voltage/current.
- Confirm ATS/transfer switch specs for safe generator-grid-solar handover.
- installer accreditation and after-sales support availability.

B.5 Next Steps for Tendering / Final Budgeting

1. Request for Quotation (RFQ) using the itemized BOM above.
2. Solicit minimum three (3) competitive quotations from reputable suppliers/contractors.
3. Evaluated based on total cost of ownership (CAPEX + expected maintenance + warranty).
4. Procurement with signed supply & installation contract including delivery schedule and performance acceptance tests.

CHANGE LOG

- Compiled itemized BOM and unit prices for the 6.2 kVA hybrid system.
- Corrected and clarified battery configuration to achieve **48 V, 400 Ah** ($8 \times 12 \text{ V}$, 200 Ah batteries).
- Added contingency, management fee, and VAT estimate.
- Included procurement checklist and next steps.

Appendix C: Data Tables

This appendix presents the **raw datasets** used for the design, fabrication, and evaluation of the hybrid solar–grid–diesel generator system. The data include solar irradiance levels, grid availability, diesel generator fuel consumption, and household demand profiles in Nigeria.

C.1 Solar Irradiance Data Across Nigeria

Table C1 shows the average **global horizontal irradiance (GHI)** for major Nigerian cities. Data were obtained from **NiMET (2023)** and **Global Solar Atlas (World Bank, 2023)**.

Table C1: Average Daily Solar Irradiance in Selected Nigerian Cities (kWh/m²/day)

City	Min (June)	Max (March)	Annual Average
Maiduguri	5.2	6.8	6.1
Kano	4.9	6.5	5.9
Abuja	4.7	6.2	5.7
Ilorin	4.4	5.8	5.3
Lagos	3.6	5.2	4.4
Port Harcourt	3.5	4.9	4.2

C.2 Grid Availability Data

Table C2 presents **average daily grid supply** (hours/day) in different Nigerian regions. Data were collated from **NERC 2023 Performance Reports** and field surveys.

Table C2: Average Grid Power Availability in Nigeria (2023)

Region	Urban (hrs/day)	Semi-urban (hrs/day)	Rural (hrs/day)
North-East	8	4	2
North-West	10	6	3
North-Central	12	8	4
South-West	14	10	6
South-East	12	9	5
South-South	10	7	4

C.3 Diesel Generator Fuel Consumption

Data were obtained from **Cummins and Mikano generator catalogs (2023)**, focusing on **5–10 kVA diesel gensets**.

Table C3: Diesel Generator Fuel Consumption Rates

Rated Power (kVA)	Load (%)	Fuel Consumption (L/hr)
5 kVA	50%	0.85
5 kVA	75%	1.15
6.5 kVA	50%	1.10
6.5 kVA	75%	1.50
10 kVA	50%	1.45
10 kVA	75%	2.10

C.4 Average Household Energy Demand Profiles

Survey results (Rural Electrification Agency, 2022; Energy Commission of Nigeria, 2023) provided **typical daily household loads**.

Table C4: Typical Nigerian Household Energy Demand (Urban vs Rural, kWh/day)

Appliance	Urban (kWh/day)	Rural (kWh/day)
Lighting (LED bulbs × 8)	1.2	0.8
Television (1 unit)	0.9	0.6
Fan (2 units)	1.4	0.8
Refrigerator (small, 150L)	1.8	0.9
Laptop/Phone charging	0.5	0.3
Water Pump (0.5 HP)	2.2	0.7
Total	8.0	4.1

Appendix D: Photographs of Prototype and Fabrication Process

This appendix presents photographic evidence of the **fabrication, assembly, and commissioning** of the 6.2 kVA hybrid solar–grid–diesel generator system. The photographs were taken during key project stages and demonstrate the practical implementation of the design.

D.1 Fabrication of Mechanical Frame

The mild steel frame was cut, welded, and reinforced to accommodate the **battery bank, inverter, control unit, and diesel generator**. Figure E1 shows the completed frame before painting.

D.2 Mounting of Battery Bank and Inverter

The 4×200 Ah deep-cycle batteries were arranged on the lower rack of the frame, while the 6.2 kVA inverter and charge controller were mounted on the upper panel. Proper ventilation spacing was ensured.

Figure D2: Installed battery bank and inverter on the fabricated frame.



D.3 Wiring of PV Modules and Electrical Integration

Four 400 W monocrystalline PV modules were connected in series-parallel configuration. The DC output was routed through the charge controller and inverter, while the ATS was wired to allow seamless switching between solar, grid, and diesel generator sources.#

D.4 Installation of Diesel Generator Backup


The 6.5 kVA diesel generator was positioned in a vibration-isolated compartment of the frame.

The exhaust was directed outside the housing for safety.

D.5 Completed Hybrid Power System

After assembly, the entire hybrid system was enclosed in a **protective galvanized sheet housing**, with cable entries fitted with grommets for dust and moisture protection.

Figure D5: Fully assembled and enclosed hybrid solar–grid–diesel generator system.



D.6 Testing and Commissioning

Final testing was carried out by loading the system with household appliances equivalent to 5.5 kW. Measurements of efficiency, voltage regulation, and fuel savings were taken.